



GENERAL NOTES:

1. EFFLUENT SUPPLY LINE MUST BE BURIED AT LEAST 36 INCHES WHEN DRAINBACK TO PUMP TANK IS NOT POSSIBLE.
2. SPRAY UNIT BASE MUST BE BEDDED IN AT LEAST 4 INCHES OF GRAVEL.
3. SPRAY UNIT MUST BE BACKFILLED WITH GRAVEL TO WITHIN 6 INCHES OF GRADE.
4. APPROPRIATE SIGNAGE MUST BE PROVIDED TO INDICATE NON-POTABLE WATER.

U.S. AND FOREIGN PATENTS PENDING © MMXVIII	norweco		DESIGN DATE	REVISION
	SPRAY IRRIGATION UNIT SPEC SHEET		DRAWN BY	NPD
			APPROVED BY	JMM
			DATE	06-04-2018
		SCALE	NTS	
THIS DRAWING IS THE PROPERTY OF NORWECO. IT IS LOANED TO YOUR COMPANY AND MAY NOT BE COPIED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN PERMISSION FROM NORWECO.		DRAWING NO.	PC-2-0021	